

KQP 000



Repair completed

Name of Company carrying out the repair: HDPS

Generator Number:	3018	Date:	11/11/2025
-------------------	------	-------	------------

Repair By:	fleet.service	Location:	CHCH
------------	---------------	-----------	------

Hours Run:	6788.00Hrs	Fuel Level:	Full
------------	------------	-------------	------

Generator Back in service date:	11/11/2025
---------------------------------	------------

Repair carried out:

Batteries flat. Remove, Charge and test.

Advise if batteries need replacing.

Fuel cap loose.