

KQP 000



Repair completed

Name of Company carrying out the repair: Heavy Diesel Dynamics

Generator Number:	GEN4031	Date:	12/11/2024
-------------------	---------	-------	------------

Repair By:	jonathan.gatman	Location:	HAM
------------	-----------------	-----------	-----

Hours Run:	2476.00Hrs	Fuel Level:	Full
------------	------------	-------------	------

Generator Back in service date:	12/11/2024
---------------------------------	------------

Repair carried out:

Test alternator for charge rate. The alternator is faulty. Removed and replaced alternator. Ran generator up and found oil leaking from oil cooler pipes. Stripped oil pipe and cleaned threads. Sealed oil pipe. Re-fit injector lines. Run generator up and check for leaks. All ok.