

KQP 000



Repair completed

Name of Company carrying out the repair: Hdps

Generator Number: 4072

Date: 09/02/2026

Repair By: fleet.service

Location: CHCH

Hours Run: 3247.00Hrs

Fuel Level: Full

Generator Back in service date: 09/02/2026

Repair carried out:

1. Alternator belt need adjusted done
2. End front door not locking/fitted another latch