

KQP 000



Repair completed

Name of Company carrying out the repair: Hdps

Generator Number: 4072

Date: 11/02/2026

Repair By: fleet.service

Location: CHCH

Hours Run: 3247.00Hrs

Fuel Level: Full

Generator Back in service date: 12/02/2026

Repair carried out:

1. Check connections at fuel solenoid coil when power up and resistance
2. Check rear of fuel pump to check sticky springs Internally
3. It is still looking like could need new coil but not faulting/Monitor