

KQP 000



Repair completed

Name of Company carrying out the repair: Hdps

Generator Number: 3061

Date: 05/03/2026

Repair By: fleet.service

Location: CHCH

Hours Run: 6653.00Hrs

Fuel Level: Full

Generator Back in service date: 09/03/2026

Repair carried out:

1. Inspect for leaks and repair ,drain bunding and reseal around plate

2. Test power to fuel gauge and diagnosis found no resistance at fuel sender wire to fuel gauge, not connected correctly

Move sender wire in to correct position retest gauge works okay, connection into plug not the best but works.