

KQP 000



## Repair completed

Name of Company carrying out the repair: Hdps

Generator Number: 2048

Date: 13/05/2026

Repair By: fleet.service

Location: CHCH

Hours Run: 3766.00Hrs

Fuel Level: Full

Generator Back in service date: 15/05/2026

Repair carried out:

1. Solenoid not operating on start motor.
2. Test starter motor and found solenoid not working ,as new starter take to supplier to be tested
3. Fitted new starter motor and found after Test wiring the controller faulty as well replace controller from 2103