

KQP 000



Repair completed

Name of Company carrying out the repair: Hdps

Generator Number: 2185

Date: 28/05/2026

Repair By: fleet.service

Location: CHCH

Hours Run: 3656.00Hrs

Fuel Level: Full

Generator Back in service date: 02/06/2026

Repair carried out:

1. Carry out ,250hr service ,twin fuel filter housing come loose, clean inspect check O rings and seal before refitted
2. Remove shroudshrouds,clean/inspect front of engine, run engine up check for leaks nothing visible
3. Removed rear panel steam clean radiator refitted panel