

KQP 000



Repair completed

Name of Company carrying out the repair: HDPS Christchurch

Generator Number: 2050

Date: 15/06/2026

Repair By: fleet.service

Location: CHCH

Hours Run: 11724.00Hrs

Fuel Level: 0.75

Generator Back in service date: 15/06/2026

Repair carried out:

Positive battery terminal captive thread pulled out of terminal causing loose connection.

Replaced battery terminal.