

KQP 000



Repair completed

Name of Company carrying out the repair: HDPS

Generator Number: 4072

Date: 17/06/2026

Repair By: fleet.service

Location: CHCH

Hours Run: 3643.00Hrs

Fuel Level: Full

Generator Back in service date: 17/06/2026

Repair carried out:

Engine cranks but will not start.
Found fuel shutoff solenoid not operating.

Tested and found fuel shutoff solenoid earth wire bad connection inside plug.