

KQP 000



Repair completed

Name of Company carrying out the repair: Hdps

Generator Number: 3101

Date: 17/06/2026

Repair By: fleet.service

Location: CHCH

Hours Run: 4557.00Hrs

Fuel Level: 0.75

Generator Back in service date: 26/06/2026

Repair carried out:

1. Check for fuel leaks and fuel run back, connect clear lines to check air bubbles notice a couple, remove filters and filter housing replace seals and filters and supply fuel line olive could move .
2. Bleed fuel system after replacement seals etc run okay easy start up, fit original other fuel lines Bleed fuel system okay