

KQP 000



## Repair completed

Name of Company carrying out the repair: Heavy Diesel Dynamics

Generator Number:	GEN3114	Date:	08/02/2025
-------------------	---------	-------	------------

Repair By:	jonathan.gatman	Location:	HAM
------------	-----------------	-----------	-----

Hours Run:	1167.00Hrs	Fuel Level:	0.25
------------	------------	-------------	------

Generator Back in service date:	08/02/2025
---------------------------------	------------

### Repair carried out:

Travel to site and repair generator leaking diesel. Replace split fuel filter. Pump 120ltrs of diesel water mix out of bund. Run generator up. All ok