

KQP 000



## Repair completed

Name of Company carrying out the repair: Heavy Diesel Dynamics

Generator Number:	GEN4153	Date:	28/02/2025
-------------------	---------	-------	------------

Repair By:	jonathan.gatman	Location:	HAM
------------	-----------------	-----------	-----

Hours Run:	3801.00Hrs	Fuel Level:	0.75
------------	------------	-------------	------

Generator Back in service date:	
---------------------------------	--

Repair carried out:

Fuel cap smashed.

Not emergency stop

Rear panel fallen off

Oil leaks

All intake brackets are broken.

Advised to have the generator grounded for repairs