

KQP 000**Repair completed**

Name of Company carrying out the repair: Heavy Diesel Dynamics

Generator Number: GEN4085

Date: 31/03/2025

Repair By: jonathan.gatman

Location: HAM

Hours Run: 5716.00Hrs

Fuel Level: 0.25

Generator Back in service date:

Repair carried out:

Travel to CT site and locate generator. Fault code showing there is no oil pressure. Fitted oil pressure tester and run generator up. oil pressure is fine. Ordered new oil pressure sender. Collected new sender and fit to generator. Run generator up. still faulting. Checked all fuses and wiring. Organize electrician to come check all wiring and main comms board. Found fault in comms board not registering oil pressure. Advised Stephen of fault and is getting generator sent to Auckland.