

KQP 000



Repair completed

Name of Company carrying out the repair: Heavy Diesel Dynamics

Generator Number:	GEN4057	Date:	16/06/2025
-------------------	---------	-------	------------

Repair By:	jonathan.gatman	Location:	HAM
------------	-----------------	-----------	-----

Hours Run:	3617.00Hrs	Fuel Level:	Full
------------	------------	-------------	------

Generator Back in service date:	16/06/2025
---------------------------------	------------

Repair carried out:

Alternator bearings failed. Removed alternator and repaired broken bracket