

KQP 000



Repair completed

Name of Company carrying out the repair: Heavy Diesel Dynamics

Generator Number:	GEN4098	Date:	01/10/2024
-------------------	---------	-------	------------

Repair By:	jonathan.gatman	Location:	HAM
------------	-----------------	-----------	-----

Hours Run:	3629.00Hrs	Fuel Level:	Full
------------	------------	-------------	------

Generator Back in service date:	01/10/2024
---------------------------------	------------

Repair carried out:

Exhaust pipe fallen out of muffler. Remove top panels. Loosen muffler. Refit exhaust and fit new clamp. Tighten muffler. Refit top panel. Run generator up and check for leaks. All ok.