

KQP 000



Repair completed

Name of Company carrying out the repair: Heavy Diesel Dynamics

| | | | |
|-------------------|---------|-------|------------|
| Generator Number: | GEN4138 | Date: | 23/10/2024 |
|-------------------|---------|-------|------------|

| | | | |
|------------|-----------------|-----------|-----|
| Repair By: | jonathan.gatman | Location: | HAM |
|------------|-----------------|-----------|-----|

| | | | |
|------------|------------|-------------|------|
| Hours Run: | 4117.00Hrs | Fuel Level: | 0.75 |
|------------|------------|-------------|------|

| | |
|---------------------------------|------------|
| Generator Back in service date: | 23/10/2024 |
|---------------------------------|------------|

Repair carried out:

Test battery. Battery tested bad. Jump started generator and check charge rate.
Alternator charge rate is good. Get new battery and check. All ok.