

KQP 071



GEN - PTI Check Sheet

Generator #:	4166	Date:	01/11/2024
Hours Run:	4307.00Hrs	Service Due Hours:	4415.00Hrs
Inspected By:	fleet.service	Location:	CHCH

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:

Oil Level	P/F
Oil Leaks	P/F
Oil Lines for Chafing	P/F/NA
Exhaust System	P/F
Engine RPM	RPM
Coolant	

Pass
Fail
Pass

Alternator:

Voltage Output	Voltage (a,b,c)
Frequency	Hz
Damaged Sockets / Pins	P/F
Switch / Circuit Breakers "On"	P/F
Battery	

Fuel System:

Fuel Lines For Chaffing	P/F
Fuel Leaks	P/F
Water in Fuel Separator (Drain)	P/F
Fuel Level	F/0.75/0.5/0.25/E

Pass
Pass
Pass
Full

Unit:

Mounts / Bolts to Skid Base	P/F
Frame Security	P/F
Engine / Alternator Mounts	P/F
Gauges	P/F
Control Box Door/Locks	P/F
Enclosure Filters	P/F

Pass
Pass
Pass
Pass
Pass
Pass

Telemetry:

Comms Functioning	P/F/NA
Mountings and Harness	P/F/NA

Pass
Pass

Comments

Coupling teeth broken off