

KQP 071



GEN - PTI Check Sheet

| | | | |
|---------------|-----------------|--------------------|------------|
| Generator #: | GEN3020 | Date: | 22/10/2025 |
| Hours Run: | 5269.00Hrs | Service Due Hours: | 0.00Hrs |
| Inspected By: | jonathan.gatman | Location: | HAM |

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:

| | |
|-----------------------|--------|
| Oil Level | P/F |
| Oil Leaks | P/F |
| Oil Lines for Chafing | P/F/NA |
| Exhaust System | P/F |
| Engine RPM | RPM |
| Coolant | |

| |
|------|
| Pass |
| Pass |
| Pass |
| Pass |
| |
| |

Alternator:

| | |
|--------------------------------|-----------------|
| Voltage Output | Voltage (a,b,c) |
| Frequency | Hz |
| Damaged Sockets / Pins | P/F |
| Switch / Circuit Breakers "On" | P/F |
| Battery | |

| | | |
|------|--|--|
| | | |
| | | |
| Pass | | |
| Pass | | |
| | | |

Fuel System:

| | |
|---------------------------------|-------------------|
| Fuel Lines For Chaffing | P/F |
| Fuel Leaks | P/F |
| Water in Fuel Separator (Drain) | P/F |
| Fuel Level | F/0.75/0.5/0.25/E |

| |
|------|
| Pass |
| Pass |
| Pass |
| 0.5 |

Unit:

| | |
|-----------------------------|-----|
| Mounts / Bolts to Skid Base | P/F |
| Frame Security | P/F |
| Engine / Alternator Mounts | P/F |
| Gauges | P/F |
| Control Box Door/Locks | P/F |
| Enclosure Filters | P/F |

| |
|------|
| Pass |
| Pass |
| Fail |
| Pass |
| Pass |
| Pass |

Telemetry:

| | |
|-----------------------|--------|
| Comms Functioning | P/F/NA |
| Mountings and Harness | P/F/NA |

| |
|------|
| Pass |
| Fail |

Comments

Rear ppanels have bbroken the bolts. Fitted nnew eengine mount bbolts. Ccoolant ssensor fault