KQP 071

# GEN - PTI Check Sheet

| | | | |
|---|---|---|---|
| Generator #: | GEN3046 | Date: | 17/11/2025 |
| Hours Run: | 4112.00Hrs | Service Due Hours: | 4360.00Hrs |
| Inspected By: | jonathan.gatman | Location: | HAM |

**(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)**

| **Engine:** | | |
|---|---|---|
| Oil Level | P/F | Pass |
| Oil Leaks | P/F | Pass |
| Oil Lines for Chafing | P/F/NA | Pass |
| Exhaust System | P/F | Pass |
| Engine RPM | RPM | 1539.00 |
| Coolant | | 100.00% |

| **Alternator:** | | | | |
|---|---|---|---|---|
| Voltage Output | Voltage (a,b,c) | 239.00 | 290.00 | 240.00 |
| Frequency | Hz | | 51.90Hz | |
| Damaged Sockets / Pins | P/F | | Pass | |
| Switch / Circuit Breakers "On" | P/F | | Pass | |
| Battery | | | 28.30 | |

| **Fuel System:** | | |
|---|---|---|
| Fuel Lines For Chaffing | P/F | Pass |
| Fuel Leaks | P/F | Pass |
| Water in Fuel Separator (Drain) | P/F | Pass |
| Fuel Level | F/0.75/0.5/0.25/E | 0.5 |
| **Unit:** | | |
| Mounts / Bolts to Skid Base | P/F | Pass |
| Frame Security | P/F | Pass |
| Engine / Alternator Mounts | P/F | Pass |
| Gauges | P/F | Pass |
| Control Box Door/Locks | P/F | Pass |
| Enclosure Filters | P/F | Pass |
| **Telemetry:** | | |
| Comms Functioning | P/F/NA | Pass |
| Mountings and Harness | P/F/NA | Pass |

Comments

Generator has been hit with fforklift

Oil leaks