



GEN - PTI Check Sheet

Generator #:	GEN4085	Date:	12/02/2026
Hours Run:		Service Due Hours:	
Inspected By:		Location:	

[Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel]

Engine:

Oil Level	P/F	
Oil Leaks	P/F	
Oil Lines for Chafing	P/F/NA	
Exhaust System	P/F	
Engine RPM	RPM	
Coolant		

Alternator:

Voltage Output	Voltage (a,b,c)	
Frequency	Hz	
Damaged Sockets / Pins	P/F	
Switch / Circuit Breakers "On"	P/F	
Battery		

Fuel System:

Fuel Lines For Chaffing	P/F	
Fuel Leaks	P/F	
Water in Fuel Separator (Drain)	P/F	
Fuel Level	F/0.75/0.5/0.25/E	

Unit:

Mounts / Bolts to Skid Base	P/F	
Frame Security	P/F	
Engine / Alternator Mounts	P/F	
Gauges	P/F	
Control Box Door/Locks	P/F	
Enclosure Filters	P/F	

Telemetry:

Comms Functioning	P/F/NA	
Mountings and Harness	P/F/NA	

Comments
Needs to be removed