KQP 071

GEN - PTI Check Sheet

Generator #:	GEN4085	Date:	12/02/2026
Hours Run:		Service Due Hours:	
Inspected By:		Location:	

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:		
Oil Level	P/F	
Oil Leaks	P/F	
Oil Lines for Chafing	P/F/NA	
Exhaust System	P/F	
Engine RPM	RPM	
Coolant		

Alternator:				
Voltage Output	Voltage (a,b,c)			
Frequency	Hz			
Damaged Sockets / Pins	P/F			
Switch / Circuit Breakers "On"	P/F			
Battery				

Fuel System:		
Fuel Lines For Chaffing	P/F	
Fuel Leaks	P/F	
Water in Fuel Separator (Drain)	P/F	
Fuel Level	F/0.75/0.5/0.25/E	
Unit:		
Mounts / Bolts to Skid Base	P/F	
Frame Security	P/F	
Engine / Alternator Mounts	P/F	
Gauges	P/F	
Control Box Door/Locks	P/F	
Enclosure Filters	P/F	
Telemetry:		
Comms Functioning	P/F/NA	
Mountings and Harness	P/F/NA	

Comments

Needs to be removed