KQP 071

GEN - PTI Check Sheet

Generator #:	GEN3033	Date:	16/02/2026
Hours Run:	6034.00Hrs	Service Due Hours:	5850.00Hrs
Inspected By:	jonathan.gatman	Location:	HAM

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:		
Oil Level	P/F	Pass
Oil Leaks	P/F	Pass
Oil Lines for Chafing	P/F/NA	Pass
Exhaust System	P/F	Pass
Engine RPM	RPM	1524.00
Coolant		100.00%

Alternator:				
Voltage Output	Voltage (a,b,c)	241.00	242.00	241.00
Frequency	Hz		51.00Hz	
Damaged Sockets / Pins	P/F		Pass	
Switch / Circuit Breakers "On"	P/F		Pass	
Battery			28.50	

Fuel System:		
Fuel Lines For Chaffing	P/F	Pass
Fuel Leaks	P/F	Pass
Water in Fuel Separator (Drain)	P/F	Pass
Fuel Level	F/0.75/0.5/0.25/E	0.5
Unit:		
Mounts / Bolts to Skid Base	P/F	Fail
Frame Security	P/F	Fail
Engine / Alternator Mounts	P/F	Fail
Gauges	P/F	Pass
Control Box Door/Locks	P/F	Pass
Enclosure Filters	P/F	Pass
Telemetry:		
Comms Functioning	P/F/NA	Pass
Mountings and Harness	P/F/NA	Fail

Comments

All rear ggenerator mounts are bbroken.

Needs to be rremoved and rrepaired