

KQP 071



GEN - PTI Check Sheet

Generator #:	4044	Date:	12/06/2026
Hours Run:	4858.00Hrs	Service Due Hours:	4877.00Hrs
Inspected By:	fleet.service	Location:	CHCH

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:

Oil Level	P/F	Pass
Oil Leaks	P/F	Pass
Oil Lines for Chafing	P/F/NA	Pass
Exhaust System	P/F	Pass
Engine RPM	RPM	1563.00
Coolant		0.00%

Alternator:

Voltage Output	Voltage (a,b,c)	417.00	412.00	417.00
Frequency	Hz		52.10Hz	
Damaged Sockets / Pins	P/F		Pass	
Switch / Circuit Breakers "On"	P/F		Pass	
Battery			12.50	

Fuel System:

Fuel Lines For Chaffing	P/F	Pass
Fuel Leaks	P/F	Pass
Water in Fuel Separator (Drain)	P/F	Pass
Fuel Level	F/0.75/0.5/0.25/E	Full

Unit:

Mounts / Bolts to Skid Base	P/F	Pass
Frame Security	P/F	Pass
Engine / Alternator Mounts	P/F	Pass
Gauges	P/F	Pass
Control Box Door/Locks	P/F	Pass
Enclosure Filters	P/F	

Telemetry:

Comms Functioning	P/F/NA	Pass
Mountings and Harness	P/F/NA	Fail

Comments

All fuel tank top straps broken. Fuel tank rubbing on engine mount.

Repair needed.

Air intake bolts loose- Tightened