KQP 071

GEN - PTI Check Sheet

Generator #:	GEN3114	Date:	14/08/2026
Hours Run:	2623.00Hrs	Service Due Hours:	2800.00Hrs
Inspected By:	mikemobmech	Location:	PNTH

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:			
Oil Level	P/F	Pass	
Oil Leaks	P/F	Pass	
Oil Lines for Chafing	P/F/NA	Pass	
Exhaust System	P/F	Pass	
Engine RPM	RPM	1560.00	
Coolant			
Alternator:			
Voltage Output	Voltage (a,b,c)	28.40	
Frequency	Hz	52.00Hz	
Damaged Sockets / Pins	P/F	Pass	
Switch / Circuit Breakers "On"	P/F	Pass	
Battery		28.20	
Fuel System:			
Fuel Lines For Chaffing	P/F	Pass	
Fuel Leaks	P/F	Pass	
Water in Fuel Separator (Drain)	P/F	Pass	
Fuel Level	F/0.75/0.5/0.25/E	Full	
Unit:			
Mounts / Bolts to Skid Base	P/F	Pass	
Frame Security	P/F	Pass	
Engine / Alternator Mounts	P/F	Pass	
Gauges	P/F	Pass	
Control Box Door/Locks	P/F	Pass	
Enclosure Filters	P/F	Pass	
Telemetry:			
Comms Functioning	P/F/NA	Pass	
Mountings and Harness	P/F/NA	Pass	

Comments