KQP 071

GEN - PTI Check Sheet

Generator #:	GEN4029	Date:	10/09/2026
Hours Run:	6510.00Hrs	Service Due Hours:	6550.00Hrs
Inspected By:	jonathan.gatman	Location:	HAM

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:				
Oil Level	P/F		Pass	
Oil Leaks	P/F		Fail	
Oil Lines for Chafing	P/F/NA		Pass	
Exhaust System	P/F		Pass	
Engine RPM	RPM		1569.00	
Coolant				
Alternator:				
Voltage Output	Voltage (a,b,c)	240.00	241.00	239.00
Frequency	Hz		52.70Hz	
Damaged Sockets / Pins	P/F		Pass	
Switch / Circuit Breakers "On"	P/F		Pass	
Battery			14.40	
Fuel System:				
Fuel Lines For Chaffing	P/F		Pass	
Fuel Leaks	P/F		Pass	
Water in Fuel Separator (Drain)	P/F		Pass	
Fuel Level	F/0.75/0.5/0.25/E		0.5	
Unit:				
Mounts / Bolts to Skid Base	P/F		Pass	
Frame Security	P/F		Pass	
Engine / Alternator Mounts	P/F		Pass	
Gauges	P/F		Pass	
Control Box Door/Locks	P/F		Pass	
Enclosure Filters	P/F		Pass	
Telemetry:				
Comms Functioning	P/F/NA		Pass	
Mountings and Harness	P/F/NA		Pass	

Comments

Cleaned up oil. Topped oil up in generator. Ran for 10mins to check for oill leaks. Generator has minor oil leaks to monitor