KQP 071

# GEN - PTI Check Sheet

| | | | |
|---|---|---|---|
| Generator #: | GEN4140 | Date: | 28/10/2026 |
| Hours Run: | 4003.00Hrs | Service Due Hours: | 4050.00Hrs |
| Inspected By: | jonathan.gatman | Location: | HAM |

**(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)**

| | | | | |
|---|---|---|---|---|
| **Engine:** | | | | |
| Oil Level | P/F | Pass | | |
| Oil Leaks | P/F | Pass | | |
| Oil Lines for Chafing | P/F/NA | Pass | | |
| Exhaust System | P/F | Pass | | |
| Engine RPM | RPM | 1563.00 | | |
| Coolant | | | | |
| **Alternator:** | | | | |
| Voltage Output | Voltage (a,b,c) | 241.00 | 239.00 | 240.00 |
| Frequency | Hz | 52.00Hz | | |
| Damaged Sockets / Pins | P/F | Pass | | |
| Switch / Circuit Breakers "On" | P/F | Pass | | |
| Battery | | 14.30 | | |
| **Fuel System:** | | | | |
| Fuel Lines For Chaffing | P/F | Pass | | |
| Fuel Leaks | P/F | Pass | | |
| Water in Fuel Separator (Drain) | P/F | Pass | | |
| Fuel Level | F/0.75/0.5/0.25/E | Full | | |
| **Unit:** | | | | |
| Mounts / Bolts to Skid Base | P/F | Pass | | |
| Frame Security | P/F | Pass | | |
| Engine / Alternator Mounts | P/F | Pass | | |
| Gauges | P/F | Pass | | |
| Control Box Door/Locks | P/F | Pass | | |
| Enclosure Filters | P/F | Pass | | |
| **Telemetry:** | | | | |
| Comms Functioning | P/F/NA | Pass | | |
| Mountings and Harness | P/F/NA | Pass | | |

Comments