

KQP 071



GEN - PTI Check Sheet

| | | | |
|---------------|-----------------|--------------------|------------|
| Generator #: | 2048 | Date: | 13/12/2024 |
| Hours Run: | 2693.00Hrs | Service Due Hours: | 2673.00Hrs |
| Inspected By: | jeremy.mcdonald | Location: | Timaru |

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:

| | | |
|-----------------------|--------|---------|
| Oil Level | P/F | Pass |
| Oil Leaks | P/F | Pass |
| Oil Lines for Chafing | P/F/NA | Pass |
| Exhaust System | P/F | Pass |
| Engine RPM | RPM | 1567.00 |
| Coolant | | |

Alternator:

| | | | | |
|--------------------------------|-----------------|--------|---------|--------|
| Voltage Output | Voltage (a,b,c) | 416.00 | 411.00 | 468.00 |
| Frequency | Hz | | 51.00Hz | |
| Damaged Sockets / Pins | P/F | | Pass | |
| Switch / Circuit Breakers "On" | P/F | | Pass | |
| Battery | | | | |

Fuel System:

| | | |
|---------------------------------|-------------------|------|
| Fuel Lines For Chaffing | P/F | Pass |
| Fuel Leaks | P/F | Pass |
| Water in Fuel Separator (Drain) | P/F | Pass |
| Fuel Level | F/0.75/0.5/0.25/E | 0.75 |

Unit:

| | | |
|-----------------------------|-----|------|
| Mounts / Bolts to Skid Base | P/F | Pass |
| Frame Security | P/F | Pass |
| Engine / Alternator Mounts | P/F | Pass |
| Gauges | P/F | Pass |
| Control Box Door/Locks | P/F | Pass |
| Enclosure Filters | P/F | Pass |

Telemetry:

| | | |
|-----------------------|--------|--|
| Comms Functioning | P/F/NA | |
| Mountings and Harness | P/F/NA | |

Comments