KQP 071

GEN - PTI Check Sheet

Generator #:	3161	Date:	08/01/2025
Hours Run:	3561.00Hrs	Service Due Hours:	3640.00Hrs
Inspected By:	fleet.service	Location:	CHCH

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:

Oil Level	P/F	Pass
Oil Leaks	P/F	Pass
Oil Lines for Chafing	P/F/NA	
Exhaust System	P/F	Pass
Engine RPM	RPM	1605.00
Coolant		52.00%

Alternator:

Voltage Output	Voltage (a,b,c)	415.00	416.00	417.00
Frequency	Hz			
Damaged Sockets / Pins	P/F		Pass	
Switch / Circuit Breakers "On"	P/F		Pass	
Battery			28.00	

Fuel System:

Fuel Lines For Chaffing	P/F	
Fuel Leaks	P/F	
Water in Fuel Separator (Drain)	P/F	
Fuel Level	F/0.75/0.5/0.25/E	

Unit:

Mounts / Bolts to Skid Base	P/F	
Frame Security	P/F	
Engine / Alternator Mounts	P/F	
Gauges	P/F	
Control Box Door/Locks	P/F	
Enclosure Filters	P/F	

Telemetry:

Comms Functioning	P/F/NA	
Mountings and Harness	P/F/NA	

Comments