KQP 071

GEN - PTI Check Sheet

Generator #:	GEN4029	Date:	21/01/2025
Hours Run:	5204.00Hrs	Service Due Hours:	5250.00Hrs
Inspected By:	jonathan.gatman	Location:	HAM

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:					
Oil Level	P/F				Pass
Oil Leaks	P/F				Pass
Oil Lines for Chafing	P/F/NA				Pass
Exhaust System	P/F				Pass
Engine RPM	RPM				1572.00
Coolant					
Alternator:					
Voltage Output	Voltage (a,b,c)	241.00	241.00	242.00	
Frequency	Hz				52.60Hz
Damaged Sockets / Pins	P/F				Pass
Switch / Circuit Breakers "On"	P/F				Pass
Battery					14.40
Fuel System:					
Fuel Lines For Chaffing	P/F				Pass
Fuel Leaks	P/F				Pass
Water in Fuel Separator (Drain)	P/F				Pass
Fuel Level	F/0.75/0.5/0.25/E				Full
Unit:					
Mounts / Bolts to Skid Base	P/F				Pass
Frame Security	P/F				Pass
Engine / Alternator Mounts	P/F				Pass
Gauges	P/F				Pass
Control Box Door/Locks	P/F				Pass
Enclosure Filters	P/F				Pass
Telemetry:					
Comms Functioning	P/F/NA				Pass
Mountings and Harness	P/F/NA				Pass

Comments

Repair fuel tank filler. Fit new bolts.