

KQP 071



**GEN - PTI Check Sheet**

Generator #:	2185	Date:	06/03/2025
Hours Run:	2762.00Hrs	Service Due Hours:	2710.00Hrs
Inspected By:	fleet.service	Location:	CHCH

**[Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel]**

**Engine:**

Oil Level	P/F	Pass
Oil Leaks	P/F	Pass
Oil Lines for Chafing	P/F/NA	
Exhaust System	P/F	Pass
Engine RPM	RPM	1517.00
Coolant		55.00%

**Alternator:**

Voltage Output	Voltage (a,b,c)	400.00	400.00	400.00
Frequency	Hz		50.30Hz	
Damaged Sockets / Pins	P/F		Pass	
Switch / Circuit Breakers "On"	P/F		Pass	
Battery			27.90	

**Fuel System:**

Fuel Lines For Chaffing	P/F	Pass
Fuel Leaks	P/F	Pass
Water in Fuel Separator (Drain)	P/F	Pass
Fuel Level	F/0.75/0.5/0.25/E	0.5

**Unit:**

Mounts / Bolts to Skid Base	P/F	Fail
Frame Security	P/F	Pass
Engine / Alternator Mounts	P/F	Pass
Gauges	P/F	Pass
Control Box Door/Locks	P/F	Pass
Enclosure Filters	P/F	Pass

**Telemetry:**

Comms Functioning	P/F/NA	
Mountings and Harness	P/F/NA	

Comments  
Battery not secure.

Rear twist lock handles bent and left hand front