



## GEN - PTI Check Sheet

Generator #:	GEN4044	Date:	04/04/2025
Hours Run:	3842.00Hrs	Service Due Hours:	3900.00Hrs
Inspected By:	jonathan.gatman	Location:	HAM

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

### Engine:

Oil Level	P/F	Fail
Oil Leaks	P/F	
Oil Lines for Chafing	P/F/NA	Pass
Exhaust System	P/F	Pass
Engine RPM	RPM	1587.00
Coolant		

### Alternator:

Voltage Output	Voltage (a,b,c)	240.00	239.00	240.00
Frequency	Hz		53.00Hz	
Damaged Sockets / Pins	P/F		Pass	
Switch / Circuit Breakers "On"	P/F		Pass	
Battery			14.30	

### Fuel System:

Fuel Lines For Chaffing	P/F	Pass
Fuel Leaks	P/F	Pass
Water in Fuel Separator (Drain)	P/F	Pass
Fuel Level	F/0.75/0.5/0.25/E	0.75

### Unit:

Mounts / Bolts to Skid Base	P/F	Pass
Frame Security	P/F	Pass
Engine / Alternator Mounts	P/F	Pass
Gauges	P/F	Pass
Control Box Door/Locks	P/F	Pass
Enclosure Filters	P/F	Pass

### Telemetry:

Comms Functioning	P/F/NA	Pass
Mountings and Harness	P/F/NA	Pass

### Comments

The intake braket is broken away. Have fitted bigger washers to secure it for now. Will need removing completely and welded. Repaired oil leak from oil pipe. Topped oil up 6.5ltrs.