KQP 071

GEN - PTI Check Sheet

Generator #:	GEN4044	Date:	04/04/2025
Hours Run:	3842.00Hrs	Service Due Hours:	3900.00Hrs
Inspected By:	jonathan.gatman	Location:	HAM

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:				
Oil Level	P/F			Fail
Oil Leaks	P/F			
Oil Lines for Chafing	P/F/NA			Pass
Exhaust System	P/F			Pass
Engine RPM	RPM			1587.00
Coolant				
Alternator:				
Voltage Output	Voltage (a,b,c)	240.00	239.00	240.00
Frequency	Hz			53.00Hz
Damaged Sockets / Pins	P/F			Pass
Switch / Circuit Breakers "On"	P/F			Pass
Battery				14.30
Fuel System:				
Fuel Lines For Chaffing	P/F			Pass
Fuel Leaks	P/F			Pass
Water in Fuel Separator (Drain)	P/F			Pass
Fuel Level	F/0.75/0.5/0.25/E			0.75
Unit:				
Mounts / Bolts to Skid Base	P/F			Pass
Frame Security	P/F			Pass
Engine / Alternator Mounts	P/F			Pass
Gauges	P/F			Pass
Control Box Door/Locks	P/F			Pass
Enclosure Filters	P/F			Pass
Telemetry:				
Comms Functioning	P/F/NA			Pass
Mountings and Harness	P/F/NA			Pass

Comments

The intake braket is broken away. Have fitted bigger washers to secure it for now. Will need removing ccompletely and welded. Repaired oil leak from oil pipe. Topped oil up 6.5ltrs.