



## GEN - PTI Check Sheet

Generator #:	2185	Date:	24/04/2025
Hours Run:	2802.00Hrs	Service Due Hours:	3012.00Hrs
Inspected By:	fleet.service	Location:	CHCH

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

### Engine:

Oil Level	P/F	Pass
Oil Leaks	P/F	Pass
Oil Lines for Chafing	P/F/NA	
Exhaust System	P/F	Pass
Engine RPM	RPM	1500.00
Coolant		

### Alternator:

Voltage Output	Voltage (a,b,c)	400.00	400.00	400.00
Frequency	Hz	50.00Hz		
Damaged Sockets / Pins	P/F	Pass		
Switch / Circuit Breakers "On"	P/F	Pass		
Battery				

### Fuel System:

Fuel Lines For Chaffing	P/F	Pass
Fuel Leaks	P/F	Pass
Water in Fuel Separator (Drain)	P/F	Pass
Fuel Level	F/0.75/0.5/0.25/E	Full

### Unit:

Mounts / Bolts to Skid Base	P/F	Pass
Frame Security	P/F	Pass
Engine / Alternator Mounts	P/F	Pass
Gauges	P/F	Pass
Control Box Door/Locks	P/F	Pass
Enclosure Filters	P/F	Pass

### Telemetry:

Comms Functioning	P/F/NA	
Mountings and Harness	P/F/NA	

Comments