KQP 071

GEN - PTI Check Sheet

Generator #:	GEN4016	Date:	05/06/2025
Hours Run:	3588.00Hrs	Service Due Hours:	3600.00Hrs
Inspected By:	jonathan.gatman	Location:	HAM

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:					
Oil Level	P/F	Pass			
Oil Leaks	P/F	Pass			
Oil Lines for Chafing	P/F/NA	Pass			
Exhaust System	P/F	Pass			
Engine RPM	RPM	1578.00			
Coolant					
Alternator:					
Voltage Output	Voltage (a,b,c)	240.00	240.00	240.00	
Frequency	Hz	52.70Hz			
Damaged Sockets / Pins	P/F	Pass			
Switch / Circuit Breakers "On"	P/F	Pass			
Battery		14.20			
Fuel System:					
Fuel Lines For Chaffing	P/F	Pass			
Fuel Leaks	P/F	Pass			
Water in Fuel Separator (Drain)	P/F	Pass			
Fuel Level	F/0.75/0.5/0.25/E	0.75			
Unit:					
Mounts / Bolts to Skid Base	P/F	Pass			
Frame Security	P/F	Pass			
Engine / Alternator Mounts	P/F	Pass			
Gauges	P/F	Pass			
Control Box Door/Locks	P/F	Pass			
Enclosure Filters	P/F	Pass			
Telemetry:					
Comms Functioning	P/F/NA	Pass			
Mountings and Harness	P/F/NA	Pass			

Comments