

KQP 071



GEN - PTI Check Sheet

Generator #:	4098	Date:	11/08/2025
Hours Run:	3908.00Hrs	Service Due Hours:	4000.00Hrs
Inspected By:	fleet.service	Location:	CHCH

[Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel]

Engine:

Oil Level	P/F	Pass
Oil Leaks	P/F	Fail
Oil Lines for Chafing	P/F/NA	
Exhaust System	P/F	Pass
Engine RPM	RPM	1590.00
Coolant		418.00%

Alternator:

Voltage Output	Voltage (a,b,c)	419.00	416.00	53.00
Frequency	Hz			
Damaged Sockets / Pins	P/F		Pass	
Switch / Circuit Breakers "On"	P/F		Pass	
Battery			14.90	

Fuel System:

Fuel Lines For Chaffing	P/F	Pass
Fuel Leaks	P/F	Pass
Water in Fuel Separator (Drain)	P/F	Pass
Fuel Level	F/0.75/0.5/0.25/E	Full

Unit:

Mounts / Bolts to Skid Base	P/F	Pass
Frame Security	P/F	Pass
Engine / Alternator Mounts	P/F	Pass
Gauges	P/F	Pass
Control Box Door/Locks	P/F	Pass
Enclosure Filters	P/F	Pass

Telemetry:

Comms Functioning	P/F/NA	Pass
Mountings and Harness	P/F/NA	Pass

Comments

Bunding needs drain.

Dip stick not going completely down- monitor.

Display cover push in.

Oil leaks left hand engine monitpr at alternator.

Oil leak oil cooler pipes.