



### GEN - PTI Check Sheet

Generator #:	2050	Date:	27/08/2025
Hours Run:	10912.00Hrs	Service Due Hours:	10950.00Hrs
Inspected By:	fleet.service	Location:	CHCH

**(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)**

**Engine:**

Oil Level	P/F	Pass
Oil Leaks	P/F	Pass
Oil Lines for Chafing	P/F/NA	NA
Exhaust System	P/F	Pass
Engine RPM	RPM	1594.00
Coolant		52.00%

**Alternator:**

Voltage Output	Voltage (a,b,c)	400.00	400.00	400.00
Frequency	Hz		53.00Hz	
Damaged Sockets / Pins	P/F		Pass	
Switch / Circuit Breakers "On"	P/F		Pass	
Battery			28.00	

**Fuel System:**

Fuel Lines For Chaffing	P/F	Pass
Fuel Leaks	P/F	Pass
Water in Fuel Separator (Drain)	P/F	Pass
Fuel Level	F/0.75/0.5/0.25/E	0.75

**Unit:**

Mounts / Bolts to Skid Base	P/F	Pass
Frame Security	P/F	Pass
Engine / Alternator Mounts	P/F	Pass
Gauges	P/F	Pass
Control Box Door/Locks	P/F	Pass
Enclosure Filters	P/F	Pass

**Telemetry:**

Comms Functioning	P/F/NA	NA
Mountings and Harness	P/F/NA	NA

Comments

FRONT RHS BASE SMALL CRACK - MONITOR