KQP 071

GEN - PTI Check Sheet

Generator #:	GEN4153	Date:	04/09/2025
Hours Run:	4202.00Hrs	Service Due Hours:	0.00Hrs
Inspected By:	jonathan.gatman	Location:	HAM

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:					
Oil Level	P/F				Pass
Oil Leaks	P/F				Fail
Oil Lines for Chafing	P/F/NA				Pass
Exhaust System	P/F				Pass
Engine RPM	RPM				1602.00
Coolant					
Alternator:					
Voltage Output	Voltage (a,b,c)	241.00	241.00	241.00	
Frequency	Hz				53.50Hz
Damaged Sockets / Pins	P/F				Pass
Switch / Circuit Breakers "On"	P/F				Pass
Battery					14.10
Fuel System:					
Fuel Lines For Chaffing	P/F				Pass
Fuel Leaks	P/F				Pass
Water in Fuel Separator (Drain)	P/F				Pass
Fuel Level	F/0.75/0.5/0.25/E				Full
Unit:					
Mounts / Bolts to Skid Base	P/F				Pass
Frame Security	P/F				Fail
Engine / Alternator Mounts	P/F				Pass
Gauges	P/F				Pass
Control Box Door/Locks	P/F				Fail
Enclosure Filters	P/F				Pass
Telemetry:					
Comms Functioning	P/F/NA				Pass
Mountings and Harness	P/F/NA				Pass

Comments

Frames and panels are bbroken. Fuel cap is smashed. Comms door is smashed.