KQP 071

GEN - PTI Check Sheet

Generator #:	2103	Date:	08/09/2025
Hours Run:	1688.00Hrs	Service Due Hours:	1734.00Hrs
Inspected By:	jeremy.mcdonald	Location:	Timaru

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:				
Oil Level	P/F			Pass
Oil Leaks	P/F			Pass
Oil Lines for Chafing	P/F/NA			Pass
Exhaust System	P/F			Pass
Engine RPM	RPM			1545.00
Coolant				
Alternator:				
Voltage Output	Voltage (a,b,c)	408.00	408.00	407.00
Frequency	Hz			51.70Hz
Damaged Sockets / Pins	P/F			Pass
Switch / Circuit Breakers "On"	P/F			Pass
Battery				
Fuel System:				
Fuel Lines For Chaffing	P/F			Pass
Fuel Leaks	P/F			Pass
Water in Fuel Separator (Drain)	P/F			Pass
Fuel Level	F/0.75/0.5/0.25/E			0.75
Unit:				
Mounts / Bolts to Skid Base	P/F			Pass
Frame Security	P/F			Pass
Engine / Alternator Mounts	P/F			Pass
Gauges	P/F			Pass
Control Box Door/Locks	P/F			Pass
Enclosure Filters	P/F			Pass
Telemetry:				
Comms Functioning	P/F/NA			
Mountings and Harness	P/F/NA			

Comments

Battery bracket - okay.