



GEN - PTI Check Sheet

Generator #:	GEN4153	Date:	12/09/2025
Hours Run:	4244.00Hrs	Service Due Hours:	0.00Hrs
Inspected By:	jonathan.gatman	Location:	HAM

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:

Oil Level	P/F	<table border="1" style="border-collapse: collapse; width: 100px; height: 100px;"> <tr><td>Fail</td></tr> <tr><td>Pass</td></tr> <tr><td>Pass</td></tr> <tr><td>Pass</td></tr> <tr><td> </td></tr> <tr><td> </td></tr> </table>	Fail	Pass	Pass	Pass		
Fail								
Pass								
Pass								
Pass								
Oil Leaks	P/F							
Oil Lines for Chafing	P/F/NA							
Exhaust System	P/F							
Engine RPM	RPM							
Coolant								

Alternator:

Voltage Output	P/F	<table border="1" style="border-collapse: collapse; width: 100px; height: 100px;"> <tr><td>Voltage (a,b,c)</td></tr> <tr><td>Hz</td></tr> <tr><td>P/F</td></tr> <tr><td>P/F</td></tr> <tr><td> </td></tr> </table>	Voltage (a,b,c)	Hz	P/F	P/F	
Voltage (a,b,c)							
Hz							
P/F							
P/F							
Frequency	P/F						
Damaged Sockets / Pins	P/F						
Switch / Circuit Breakers "On"	P/F						
Battery							

Fuel System:

Fuel Lines For Chaffing	P/F	<table border="1" style="border-collapse: collapse; width: 100px; height: 100px;"> <tr><td> </td></tr> <tr><td> </td></tr> <tr><td> </td></tr> <tr><td> </td></tr> </table>				
Fuel Leaks	P/F					
Water in Fuel Separator (Drain)	P/F					
Fuel Level	F/0.75/0.5/0.25/E					

Unit:

Mounts / Bolts to Skid Base	P/F	<table border="1" style="border-collapse: collapse; width: 100px; height: 100px;"> <tr><td> </td></tr> </table>							
Frame Security	P/F								
Engine / Alternator Mounts	P/F								
Gauges	P/F								
Control Box Door/Locks	P/F								
Enclosure Filters	P/F								

Telemetry:

Comms Functioning	P/F/NA	<table border="1" style="border-collapse: collapse; width: 100px; height: 100px;"> <tr><td> </td></tr> <tr><td> </td></tr> </table>		
Mountings and Harness	P/F/NA			

Comments

Needs to be removed for rrepairs