

KQP 071



GEN - PTI Check Sheet

Generator #:	3018	Date:	03/10/2025
Hours Run:	6955.00Hrs	Service Due Hours:	6680.00Hrs
Inspected By:	fleet.service	Location:	CHCH

[Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel]

Engine:

Oil Level	P/F	Pass
Oil Leaks	P/F	Fail
Oil Lines for Chafing	P/F/NA	
Exhaust System	P/F	Pass
Engine RPM	RPM	1515.00
Coolant		50.00%

Alternator:

Voltage Output	Voltage (a,b,c)	402.00	401.00	403.00
Frequency	Hz		52.40Hz	
Damaged Sockets / Pins	P/F		Pass	
Switch / Circuit Breakers "On"	P/F		Pass	
Battery			28.50	

Fuel System:

Fuel Lines For Chaffing	P/F	Pass
Fuel Leaks	P/F	Pass
Water in Fuel Separator (Drain)	P/F	Fail
Fuel Level	F/0.75/0.5/0.25/E	Full

Unit:

Mounts / Bolts to Skid Base	P/F	Fail
Frame Security	P/F	Pass
Engine / Alternator Mounts	P/F	Fail
Gauges	P/F	Pass
Control Box Door/Locks	P/F	Fail
Enclosure Filters	P/F	Pass

Telemetry:

Comms Functioning	P/F/NA	Pass
Mountings and Harness	P/F/NA	Pass

Comments
250HR SERVICE

- Rocker cover gasket leaking- requires top tune.
- Alternator cross member missing bolts/cracks.
- Battery box not secure.
- Bunding need drain.
- Right hand rear door not locking.
- Fuel Gauges not working.
- Radiator shroud cracked.
- Check oil leak.