KQP 071

GEN - PTI Check Sheet

Generator #:	3018	Date:	03/10/2025
Hours Run:	6955.00Hrs	Service Due Hours:	6680.00Hrs
Inspected By:	fleet.service	Location:	CHCH

(Key: P/F – Pass /Fail, RPM – Revs per Minute, F – Fuel)

Engine:				
Oil Level	P/F	Pass		
Oil Leaks	P/F	Fail		
Oil Lines for Chafing	P/F/NA			
Exhaust System	P/F	Pass		
Engine RPM	RPM	1515.00		
Coolant		50.00%		
Alternator:				
Voltage Output	Voltage (a,b,c)	402.00	401.00	403.00
Frequency	Hz	52.40Hz		
Damaged Sockets / Pins	P/F	Pass		
Switch / Circuit Breakers "On"	P/F	Pass		
Battery		28.50		
Fuel System:				
Fuel Lines For Chaffing	P/F	Pass		
Fuel Leaks	P/F	Pass		
Water in Fuel Separator (Drain)	P/F	Fail		
Fuel Level	F/0.75/0.5/0.25/E	Full		
Unit:				
Mounts / Bolts to Skid Base	P/F	Fail		
Frame Security	P/F	Pass		
Engine / Alternator Mounts	P/F	Fail		
Gauges	P/F	Pass		
Control Box Door/Locks	P/F	Fail		
Enclosure Filters	P/F	Pass		
Telemetry:				
Comms Functioning	P/F/NA	Pass		
Mountings and Harness	P/F/NA	Pass		

Comments

250HR SERVICE

Rocker cover gasket leaking- requires top tune.
Alternator cross member missing bolts/cracks.
Battery box not secure.
Bunding need drain.
Right hand rear door not locking.
Fuel Gauges not working.
Radiator shroud cracked.
Check oil leak.